

PWC-1



Biological Water Clarifier

GENERAL INSTRUCTIONS

INITIAL DOSE

Use 1 gallon of **PWC-1**° per 5,000 – 10,000 gallons of water in the system. Use the heavier dose (1:5K ratio) for high bio-load situations.

MAINTENANCE DOSE

Use one gallon of **PWC-1°** per month per 10,000 to 50,000 gallons of water in the system. Maintenance treatments should begin the next day after the initial dose. Use heavier dose (1:10K ratio) for high bio-load situations.

Active Ingredients

Pseudomonas fluorescens Pseudoxanthomonas mexicana Bacillus licheniformis Brevibacillus parabrevis Nitratireductor aquibiodomus	2 x 10 ⁶	CFU/ml CFU/ml CFU/ml CFU/ml
Total CFU per milliliter at the time of manufacture is	1 x10 ⁷	CFU/ml

This product contains live microorganisms and may cause adverse effects to persons with compromised immune system. Avoid contact with eyes, mouth and broken skin. Do not inhale product. Wear eye and skin protection when handling. Wash hands after using. Keep out of reach of children and pets.

Store out of direct sunlight. Best if stored between 40 °F and 90 °F. Gently shake before use.

EXPIRATION DATE

BATCH

Manufactured by: Micro-TES, Inc. 12500 Network Blvd. Suite 201, San Antonio, TX 78249 For more information on this product: Tel. 210 558.47.57 info@liventia.net

Micro-Tes, Inc. dba Liventia.

1 gal 2.5 gal 5 gal 55 gal _____